



15 November 2016

Addendum 2

Swansboro Public Safety
Bunk Room Addition

The following addendum shall supersede previous information and does hereby become part of the contract documents.

- Clarification: The base bid ductless split system outdoor heat pump unit (DHP-1) should be revised to Mitsubishi model MXZ-3B24A. The add alternate 2 ductless split system outdoor heat pump unit (DHP-1) should be revised to Mitsubishi model MXZ-3B24A.

End of Addendum 2